780 CMR 9.00 Fire Protection and Life Safety Systems

912.3 Location: Fire department connections shall be located in a location approved by the fire department. Such connections shall be located so that immediate access is provided to the fire department. Fire department connections shall not be obstructed by fences, brushes bushes, trees, walls or any other similar object.